

TEST REPORT

Report NO. : TB-20-01107A

C-20-02857

Page NO. : 1 OF 1

Date of Report: Mar. 18, 2020

Project Name : Self Evaluation

Contractor

Applicant : Keding Enterprises Co., Ltd.

Supplier

Sample Name : KD Prefinished Veneer Panel

Sample Submitted By : Keding Enterprises Co.,Ltd.- Chung-Hong Tsai

Date of Sample Received : Mar. 02, 2020

Date of Testing : Mar. 02, 2020 ~ Mar. 18, 2020

: 1. The information mentioned in the above section is provided by Applicant Remark

(Exclude Date of Sample Received and Date of Testing) 2. The following report content marks # is provided by Client.

Test Results

Test Item	Test Results	Test Method
Acid resistance (5% H_2SO_4 , room temperature for 24 h)	No abnormality in acid dipping test	CNS 10757(1995)

Note1: Test location is the same as the laboratory address.

Note2: This test report is an additional original report of TB-20-01107 C-20-02857. Issued date: Mar. 18, 2020.

The required specification(s) offered in this test report is/are for reference only. The conformity judgment is at the Applicant's final verdict.

Signed for and on behalf of SGS TAIWAN Ltd.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

TWC 8 6 2 6 7 0 7

No. 9, 14th Rd. Taichung Industrial Park, Taichung 40755, Taiwan / 40755 台中市台中工業區14路9號 t (886-4) 2359-1515 www.sgs.com.tw